

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Monitoring Reporting Requirements Not Met for**  
**PENDLETON COUNTY PSD RIVERTON WV3303614**

Our water system violated drinking water monitoring requirements within the past year. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

*We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time*

**What should I do?**

At this time, there is nothing you need to do.

The table below lists the monitoring we did not conduct, other violations, and the associated compliance period.

<b>Monitoring Violation</b>	<b>Fed Report #</b>	<b>Monitoring Frequency</b>	<b>Compliance Period</b>
03, NITRATE, Results Not Reported as Required	2019-9617	Yearly	2018
27, CHLORINE, Results Not Reported with Coliform Sample	2019-38	Monthly	SEP 2018
3A, E COLI, Valid Compliance Coliform Sample(s) Not Reported	2019-39	Monthly	SEP 2018

**What happened? What is being done?** (Describe corrective action)

The Nitrate sample was within the required level but was collected at the incorrect location. To make certain that future samples will be taken at the required location.

The TCR water quality was acceptable, but due to a clerical error, samples were not entered and a violation was issued.

For more information, please contact Stephen Lee Roberson at 304-358-2583 or P. O. Box 861 Franklin, WV 26807-0861.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Prepared: May 18, 2020

Date Distributed May 28, 2020

1c