

FRANKLIN, MUNICIPALITY OF

WV3303602

Consumer Confidence Report - 2023

Covering Calendar Year - 2022

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality or if you have questions, comments or suggestions, please attend any regularly scheduled water board meeting held on the second Tuesday of each month at 6 p.m. at the Town Office or call the Town Office at 304-358-7525 or William Waggy at 304-358-2984.

Your water comes from:

Source Name	Source Water Type
TOWN SPRING	Surface Water

Buyer Name	Seller Name
There are no additional purchases to display.	

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 1402 and is required to test a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2022 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2022. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): not detected at or above the MDL (Method Detection Limit).

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: FRANKLIN, MUNICIPALITY OF								
Microbiological	Result		MCL		MCLG		Typical Source	
No Detected Results were Found in the Calendar Year of 2022								
Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source	
BARIUM	8/9/2022	0.0136	0.0136	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
CHROMIUM	8/9/2022	0.94	0.94	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits	
NITRATE	8/9/2022	0.46	0.46	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
NITRATE-NITRITE	9/20/2021	0.4	0.4	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCL G	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	SMITH CREEK	2022	9	2.41 - 12	ppb	60	0	By-product of drinking water disinfection
TTHM	Smith Creek	2022	8	<0.47 - 10	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2018 - 2020	0.0631	0.0114 - 0.214	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2018 - 2020	5.1	0.18 - 37.4	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

FRANKLIN, MUNICIPALITY OF is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located at the Town Office, if you have any questions about our inventory, please contact the Town Office at 304-358-7525.

Chlorine/Chloramines Year Sampled	RANGE	RANGE Units	MRDL	MRDL Units	TYPICAL SOURCE
2022	1.40 - 1.86	MG/L	4.0	MG/L	Water additive used to control microbes

Chlorine/Chloramines Maximum Disinfection Level		MPA	MPA Units	RAA	RAA Units
2022 - 2022		1.74	MG/L	1.6	MG/L

Unresolved Deficiency Date Identified	Facility	Comments
05/10/2021	WATER SYSTEM	water system previously had waiver which allowed plant to operate unattended; the core instrumentation and controls to shut the plant down if either the turbidigy increases to set level or cholorine residual decreases to set level is still in place and operational but the permit expired - 15 years ago and the water system must re-apply for the waiver + comply with all new requirements of DW-36 or maintain Class II operator present at all times water is being produced.
05/10/2021	HANOVER STORAGE TANK	tank exterior in extremely poor condition with severe rust/corrosion present to be remedied in upcoming water project
05/10/2021	HANOVER STORAGE TANK	overflow does not extend down 1' above ground level discharging to splash pad/ drainage swale to be remedied in upcoming water project

Analyte	Facility	Highest Value	Unit of Measure	Month Occurred
TURBIDITY	TREATMENT PLANT	0.04	NTU	JUL 2022

Radiological Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
GROSS, ALPHA, EXCL. RADON & U	2/6/2019	0.029	0.029	pCi/L	15	0	Erosion of natural deposits

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	8/9/2022	98.2	45.7 - 98.2	MG/L	10000
CARBON, TOTAL	5/18/2022	1.2	0 - 1.2	ppm	10000
FREE RESIDUAL CHLORINE	11/16/2021	1.88	1.88	ppm	
NICKEL	8/9/2022	0.00057	0.00057	MG/L	0.1
SODIUM	8/9/2022	3.96	3.96	MG/L	1000
SULFATE	4/27/2021	5.8	5.8	MG/L	250
TEMPERATURE (CENTIGRADE)	6/12/2018	7.8	7.8	C	

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
FRANKLIN, MUNCIPALITY OF	03	TIER 3	SYNTHETIC ORGANICS 2	1/1/2020 to 12/31/2022

Additional Required Health Effects Language:

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761).

There are no additional required health effects violation notices.

There are no additional required health effects violation notices.

There are no additional required health effects notices.

Your CCR is available upon request by contacting the Town Office at 304-358-7525.